



VALIDATION, CERTIFICATION REPORT

Dear Mr. Revis,

Results from the ChemFree Pro saving validation were the following,

They were performed on a 500 tons chilled at 480 volt

Chemical free treatment, no chemicals used.

Zero Blow Down total water savings in this month 328, 320 gallons

Energy saving of 36.7 amperes after one month using the ChemFree Pro.

Thank you for this opportunity.

Cordially

Eng. Marcos Corraliza
President

M&G Instrumentation Cal. Services, Inc.





CALIBRATION DATA FORM

Customer:	Chem Free Pro, Inc.	Equipment Description:	Chem Free Pro
Customer Id No:	N/A	Model:	2 Inches
Contact Person:	Mr. Doyle Rvis	Manufacturer:	Chem Free Pro, Inc.
Location:	N/A	Serial No:	N/A
Calibration Date:	Mar, 2010	Range:	MFG Spec's
Next Calibration:	Mar, 2011	Procedure No:	MG-28
Frequency:	12 month	Accuracy:	N/A
Calibrated By:	M. Corraliza		

CALIBRATION DATA

Validation	Standard	Before Reading	After Reading	Deviation
Blow Down Flow	Flow	7.5 g/min.	0.0 g/min.	0.0
Amperage	Amperage	Amperage		
Ch A		236	201	035
Ch B		241	199	042
Ch C		239	206	033

Average: 36.7

Test were performed on a 500 tons chilled at 480 volt
 Chemical free treatment, no chemicals used.
 Zero Blow down total water saving in this month 328,320 gallons
 Amperage saving of 36.7 amps. after one month

CALIBRATION STANDARD

Standard Description	Manufacturer	Serial No. Lot. No.	Cal. By	Traceability N.I.S.T	Cal. Date	Cal. Due
Volt tester	Fluke	2X-013	RL	77/8817	8/2009	8/2010

CERTIFICACION DE CALIBRACION: M&G CERTIFIES THE EQUIPMENT(S) ABOVE HAS BEEN CALIBRATED WITH THE STANDARDS THAT ARE CALIBRATED AS PER MANUFACTURER'S AND M&G RECOMMENDATIONS AND WHOSE ACCURACY IS TRACEABLE TO: THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY (N.I.S.T.)

Calibration Specialist: _____